



Product Guide

Service Coils


Service Coils



The Premier Replacement Coil for Any System

- Service coil for indoor coil replacement only; for new systems, please see our HE series product line
- Same features as rated coils
- Perfect replacement for 8–12 SEER coils
- Sized for legacy installations
- Supplied with pistons for both R-22 and R-410A applications
- Access port for easy TXV installation
- “No Hassle” 5-year warranty

Microban[®], a recognized consumer brand antimicrobial additive, inhibits the growth of mold and mildew on the drain pan



Standard plastic pan with visible mold



Plastic pan with Microban[®] antimicrobial additive



Green & red drain pan plugs to identify primary vs. secondary

Product Nomenclature



Made in the USA
from US and imported parts

S 24 R 145

Product Line

S: Service Coil

Nominal MBTUH

Configurations

- R: Right Hand Upflow (CU)
- L: Left Hand Upflow (CU)
- H: Horizontal (AL)
- S: Horizontal Slab (CU)

(Multi-position option not available)

Width/Height

Cased

145: 14.5"
175: 17.5"
210: 21.0"
245: 24.5"

Uncased

130: 13.0"
140: 14.0"
155: 15.5"
170: 17.5"
200: 20.0"

Horizontal

145: 14.5"
175: 17.5"
210: 21.0"
245: 24.5"

Slab

187: 18.75"
227: 22.75"

(see charts below for available sizes)

Upflow Specifications

Model Number	Cased Width				Uncased Width				
	14.5"	17.5"	21"	24.5"	13"	14"	15.5"	17"	20"
S 24 (R,L)	X				X	X			
S 30 (R,L)	X	X			X	X	X		
S 36 (R,L)	X	X	X			X	X	X	
S 42 (R,L)		X	X				X	X	
S 48 (R,L)		X	X					X	X
S 60 (R,L)			X	X					X

Piston Kit Sizes

MBTUH	R-22	R-410A
24	59	53
30	67	59
36	73	67
42	80	73
48	84	76
60	93	

Horizontal Specifications

Model Number	Horizontal			
	14.5"	17.5"	21"	24.5"
S 24 H	X			
S 36 H	X	X		
S 48 H		X	X	
S 60 H			X	X

Horizontal Slab Specifications

Model Number	Low Profile 18.75" Slab			Standard 22.75" Slab			
	23"	27"	35"	23"	27"	35"	47"
S 24 S	X			X			
S 36 S		X			X		
S 48 S			X			X	
S 60 S			X				X

Proudly distributed by:

2175 West Park Place Boulevard
Stone Mountain, Georgia 30087
www.adpnow.com



SL-SC-03
April 2018